



## Summary of Glazed Modular Thin Brick Test Results

### Material Description

1/2" and 5/8" Thick Modular Size

Matte and Gloss, Glazed

Type: TBX (Select) Exterior Grade

### Glaze Finish & Appearance

Meets ASTM C126 Standard Specification for Ceramic Glazed Structural Clay Facing Tile, Facing Brick, and Solid Masonry Units

Tested in accordance with ASTM C67/C67M-18 Standard Test Methods for Sampling and Testing Brick and Structural Clay Tile

Specifications	Test	Standard	Reported Test Results
Imperviousness	C67/C67M-18	As Reported	No stain could be seen from a distance of five feet.
Opacity	C67/C67M-18	As Reported	No discoloration of the body was visible through the glaze.
Resistance to Crazeing	C67/C67M-18	As Reported	The glaze did not craze, spall or crack.
Resistance to Fading	C67/C67M-18	As Reported	The color and the texture of the glaze did not change.
Scratch Resistance and Hardness	Moh's Hardness	As Reported	Specimens rated above five on the Moh's Hardness Scale.